

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/155/26	Model No.: MARQ-6-50%	Date: 27-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 155/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15401 To 15500 And 15405A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15405A and removed from the Lot/Batch							
15401	Pass	15402	Pass	15403	Pass	15404	Pass
15405	Pass	15406	Pass	15407	Pass	15408	Pass
15409	Pass	15410	Pass	15411	Pass	15412	Pass
15413	Pass	15414	Pass	15415	Pass	15416	Pass
15417	Pass	15418	Pass	15419	Pass	15420	Pass
15421	Pass	15422	Pass	15423	Pass	15424	Pass
15425	Pass	15426	Pass	15427	Pass	15428	Pass
15429	Pass	15430	Pass	15431	Pass	15432	Pass
15433	Pass	15434	Pass	15435	Pass	15436	Pass
15437	Pass	15438	Pass	15439	Pass	15440	Pass
15441	Pass	15442	Pass	15443	Pass	15444	Pass
15445	Pass	15446	Pass	15447	Pass	15448	Pass
15449	Pass	15450	Pass	15451	Pass	15452	Pass
15453	Pass	15454	Pass	15455	Pass	15456	Pass
15457	Pass	15458	Pass	15459	Pass	15460	Pass
15461	Pass	15462	Pass	15463	Pass	15464	Pass
15465	Pass	15466	Pass	15467	Pass	15468	Pass
15469	Pass	15470	Pass	15471	Pass	15472	Pass
15473	Pass	15474	Pass	15475	Pass	15476	Pass
15477	Pass	15478	Pass	15479	Pass	15480	Pass
15481	Pass	15482	Pass	15483	Pass	15484	Pass
15485	Pass	15486	Pass	15487	Pass	15488	Pass
15489	Pass	15490	Pass	15491	Pass	15492	Pass
15493	Pass	15494	Pass	15495	Pass	15496	Pass
15497	Pass	15498	Pass	15499	Pass	15500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory