

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/179/26	Model No.: MARQ-6-50%	Date: 13-04-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 179/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17801 To 17900 And 17805A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17805A and removed from the Lot/Batch							
17801	Pass	17802	Pass	17803	Pass	17804	Pass
17805	Pass	17806	Pass	17807	Pass	17808	Pass
17809	Pass	17810	Pass	17811	Pass	17812	Pass
17813	Pass	17814	Pass	17815	Pass	17816	Pass
17817	Pass	17818	Pass	17819	Pass	17820	Pass
17821	Pass	17822	Pass	17823	Pass	17824	Pass
17825	Pass	17826	Pass	17827	Pass	17828	Pass
17829	Pass	17830	Pass	17831	Pass	17832	Pass
17833	Pass	17834	Pass	17835	Pass	17836	Pass
17837	Pass	17838	Pass	17839	Pass	17840	Pass
17841	Pass	17842	Pass	17843	Pass	17844	Pass
17845	Pass	17846	Pass	17847	Pass	17848	Pass
17849	Pass	17850	Pass	17851	Pass	17852	Pass
17853	Pass	17854	Pass	17855	Pass	17856	Pass
17857	Pass	17858	Pass	17859	Pass	17860	Pass
17861	Pass	17862	Pass	17863	Pass	17864	Pass
17865	Pass	17866	Pass	17867	Pass	17868	Pass
17869	Pass	17870	Pass	17871	Pass	17872	Pass
17873	Pass	17874	Pass	17875	Pass	17876	Pass
17877	Pass	17878	Pass	17879	Pass	17880	Pass
17881	Pass	17882	Pass	17883	Pass	17884	Pass
17885	Pass	17886	Pass	17887	Pass	17888	Pass
17889	Pass	17890	Pass	17891	Pass	17892	Pass
17893	Pass	17894	Pass	17895	Pass	17896	Pass
17897	Pass	17898	Pass	17899	Pass	17900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory