

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/180/26	Model No.: MARQ-6-50%	Date: 13-04-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 180/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17901 To 18000 And 17905A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17905A and removed from the Lot/Batch							
17901	Pass	17902	Pass	17903	Pass	17904	Pass
17905	Pass	17906	Pass	17907	Pass	17908	Pass
17909	Pass	17910	Pass	17911	Pass	17912	Pass
17913	Pass	17914	Pass	17915	Pass	17916	Pass
17917	Pass	17918	Pass	17919	Pass	17920	Pass
17921	Pass	17922	Pass	17923	Pass	17924	Pass
17925	Pass	17926	Pass	17927	Pass	17928	Pass
17929	Pass	17930	Pass	17931	Pass	17932	Pass
17933	Pass	17934	Pass	17935	Pass	17936	Pass
17937	Pass	17938	Pass	17939	Pass	17940	Pass
17941	Pass	17942	Pass	17943	Pass	17944	Pass
17945	Pass	17946	Pass	17947	Pass	17948	Pass
17949	Pass	17950	Pass	17951	Pass	17952	Pass
17953	Pass	17954	Pass	17955	Pass	17956	Pass
17957	Pass	17958	Pass	17959	Pass	17960	Pass
17961	Pass	17962	Pass	17963	Pass	17964	Pass
17965	Pass	17966	Pass	17967	Pass	17968	Pass
17969	Pass	17970	Pass	17971	Pass	17972	Pass
17973	Pass	17974	Pass	17975	Pass	17976	Pass
17977	Pass	17978	Pass	17979	Pass	17980	Pass
17981	Pass	17982	Pass	17983	Pass	17984	Pass
17985	Pass	17986	Pass	17987	Pass	17988	Pass
17989	Pass	17990	Pass	17991	Pass	17992	Pass
17993	Pass	17994	Pass	17995	Pass	17996	Pass
17997	Pass	17998	Pass	17999	Pass	18000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory