

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A90/RQ/029/26      | Model No.: KFARQ-6-90%                                          | Date: 17-01-2026 |
| Type and Capacity of Extinguisher | : KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ90%6 029/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 02801 To 2900 And 2805A                                       |                  |
| Month of Manufacturing            | : Jan/26                                                        |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 2805A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 2801                                                         | Pass   | 2802     | Pass   | 2803     | Pass   | 2804     | Pass   |
| 2805                                                         | Pass   | 2806     | Pass   | 2807     | Pass   | 2808     | Pass   |
| 2809                                                         | Pass   | 2810     | Pass   | 2811     | Pass   | 2812     | Pass   |
| 2813                                                         | Pass   | 2814     | Pass   | 2815     | Pass   | 2816     | Pass   |
| 2817                                                         | Pass   | 2818     | Pass   | 2819     | Pass   | 2820     | Pass   |
| 2821                                                         | Pass   | 2822     | Pass   | 2823     | Pass   | 2824     | Pass   |
| 2825                                                         | Pass   | 2826     | Pass   | 2827     | Pass   | 2828     | Pass   |
| 2829                                                         | Pass   | 2830     | Pass   | 2831     | Pass   | 2832     | Pass   |
| 2833                                                         | Pass   | 2834     | Pass   | 2835     | Pass   | 2836     | Pass   |
| 2837                                                         | Pass   | 2838     | Pass   | 2839     | Pass   | 2840     | Pass   |
| 2841                                                         | Pass   | 2842     | Pass   | 2843     | Pass   | 2844     | Pass   |
| 2845                                                         | Pass   | 2846     | Pass   | 2847     | Pass   | 2848     | Pass   |
| 2849                                                         | Pass   | 2850     | Pass   | 2851     | Pass   | 2852     | Pass   |
| 2853                                                         | Pass   | 2854     | Pass   | 2855     | Pass   | 2856     | Pass   |
| 2857                                                         | Pass   | 2858     | Pass   | 2859     | Pass   | 2860     | Pass   |
| 2861                                                         | Pass   | 2862     | Pass   | 2863     | Pass   | 2864     | Pass   |
| 2865                                                         | Pass   | 2866     | Pass   | 2867     | Pass   | 2868     | Pass   |
| 2869                                                         | Pass   | 2870     | Pass   | 2871     | Pass   | 2872     | Pass   |
| 2873                                                         | Pass   | 2874     | Pass   | 2875     | Pass   | 2876     | Pass   |
| 2877                                                         | Pass   | 2878     | Pass   | 2879     | Pass   | 2880     | Pass   |
| 2881                                                         | Pass   | 2882     | Pass   | 2883     | Pass   | 2884     | Pass   |
| 2885                                                         | Pass   | 2886     | Pass   | 2887     | Pass   | 2888     | Pass   |
| 2889                                                         | Pass   | 2890     | Pass   | 2891     | Pass   | 2892     | Pass   |
| 2893                                                         | Pass   | 2894     | Pass   | 2895     | Pass   | 2896     | Pass   |
| 2897                                                         | Pass   | 2898     | Pass   | 2899     | Pass   | 2900     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**