

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/130/26	Model No.: KFARQ-6-50%	Date: 27-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 130/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12901 To 13000 And 12905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12905A and removed from the Lot/Batch							
12901	Pass	12902	Pass	12903	Pass	12904	Pass
12905	Pass	12906	Pass	12907	Pass	12908	Pass
12909	Pass	12910	Pass	12911	Pass	12912	Pass
12913	Pass	12914	Pass	12915	Pass	12916	Pass
12917	Pass	12918	Pass	12919	Pass	12920	Pass
12921	Pass	12922	Pass	12923	Pass	12924	Pass
12925	Pass	12926	Pass	12927	Pass	12928	Pass
12929	Pass	12930	Pass	12931	Pass	12932	Pass
12933	Pass	12934	Pass	12935	Pass	12936	Pass
12937	Pass	12938	Pass	12939	Pass	12940	Pass
12941	Pass	12942	Pass	12943	Pass	12944	Pass
12945	Pass	12946	Pass	12947	Pass	12948	Pass
12949	Pass	12950	Pass	12951	Pass	12952	Pass
12953	Pass	12954	Pass	12955	Pass	12956	Pass
12957	Pass	12958	Pass	12959	Pass	12960	Pass
12961	Pass	12962	Pass	12963	Pass	12964	Pass
12965	Pass	12966	Pass	12967	Pass	12968	Pass
12969	Pass	12970	Pass	12971	Pass	12972	Pass
12973	Pass	12974	Pass	12975	Pass	12976	Pass
12977	Pass	12978	Pass	12979	Pass	12980	Pass
12981	Pass	12982	Pass	12983	Pass	12984	Pass
12985	Pass	12986	Pass	12987	Pass	12988	Pass
12989	Pass	12990	Pass	12991	Pass	12992	Pass
12993	Pass	12994	Pass	12995	Pass	12996	Pass
12997	Pass	12998	Pass	12999	Pass	13000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory