

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/111/26	Model No.: MARQ-6-50%	Date: 09-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 111/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11001 To 11100 And 11005A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11005A and removed from the Lot/Batch							
11001	Pass	11002	Pass	11003	Pass	11004	Pass
11005	Pass	11006	Pass	11007	Pass	11008	Pass
11009	Pass	11010	Pass	11011	Pass	11012	Pass
11013	Pass	11014	Pass	11015	Pass	11016	Pass
11017	Pass	11018	Pass	11019	Pass	11020	Pass
11021	Pass	11022	Pass	11023	Pass	11024	Pass
11025	Pass	11026	Pass	11027	Pass	11028	Pass
11029	Pass	11030	Pass	11031	Pass	11032	Pass
11033	Pass	11034	Pass	11035	Pass	11036	Pass
11037	Pass	11038	Pass	11039	Pass	11040	Pass
11041	Pass	11042	Pass	11043	Pass	11044	Pass
11045	Pass	11046	Pass	11047	Pass	11048	Pass
11049	Pass	11050	Pass	11051	Pass	11052	Pass
11053	Pass	11054	Pass	11055	Pass	11056	Pass
11057	Pass	11058	Pass	11059	Pass	11060	Pass
11061	Pass	11062	Pass	11063	Pass	11064	Pass
11065	Pass	11066	Pass	11067	Pass	11068	Pass
11069	Pass	11070	Pass	11071	Pass	11072	Pass
11073	Pass	11074	Pass	11075	Pass	11076	Pass
11077	Pass	11078	Pass	11079	Pass	11080	Pass
11081	Pass	11082	Pass	11083	Pass	11084	Pass
11085	Pass	11086	Pass	11087	Pass	11088	Pass
11089	Pass	11090	Pass	11091	Pass	11092	Pass
11093	Pass	11094	Pass	11095	Pass	11096	Pass
11097	Pass	11098	Pass	11099	Pass	11100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A blue ink signature is written over the stamp.

Authorized Signatory