

# HYDRO PRESSURE TEST

|                                   |                                                                       |                  |
|-----------------------------------|-----------------------------------------------------------------------|------------------|
| TC No.: HPT/D6/S/RQ/005/26        | Model No.: KFDRQ-6-S                                                  | Date: 22-03-2026 |
| Type and Capacity of Extinguisher | : KFDRQ-6-S-Kanex BC Dry Powder (SBC) CP Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFDRQ6S 005/26                                                      |                  |
| Batch Quantity                    | : 101.00 Nos.                                                         |                  |
| Serial Numbers                    | : 00401 To 500 And 405A                                               |                  |
| Month of Manufacturing            | : Mar/26                                                              |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 405A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 401                                                         | Pass   | 402      | Pass   | 403      | Pass   | 404      | Pass   |
| 405                                                         | Pass   | 406      | Pass   | 407      | Pass   | 408      | Pass   |
| 409                                                         | Pass   | 410      | Pass   | 411      | Pass   | 412      | Pass   |
| 413                                                         | Pass   | 414      | Pass   | 415      | Pass   | 416      | Pass   |
| 417                                                         | Pass   | 418      | Pass   | 419      | Pass   | 420      | Pass   |
| 421                                                         | Pass   | 422      | Pass   | 423      | Pass   | 424      | Pass   |
| 425                                                         | Pass   | 426      | Pass   | 427      | Pass   | 428      | Pass   |
| 429                                                         | Pass   | 430      | Pass   | 431      | Pass   | 432      | Pass   |
| 433                                                         | Pass   | 434      | Pass   | 435      | Pass   | 436      | Pass   |
| 437                                                         | Pass   | 438      | Pass   | 439      | Pass   | 440      | Pass   |
| 441                                                         | Pass   | 442      | Pass   | 443      | Pass   | 444      | Pass   |
| 445                                                         | Pass   | 446      | Pass   | 447      | Pass   | 448      | Pass   |
| 449                                                         | Pass   | 450      | Pass   | 451      | Pass   | 452      | Pass   |
| 453                                                         | Pass   | 454      | Pass   | 455      | Pass   | 456      | Pass   |
| 457                                                         | Pass   | 458      | Pass   | 459      | Pass   | 460      | Pass   |
| 461                                                         | Pass   | 462      | Pass   | 463      | Pass   | 464      | Pass   |
| 465                                                         | Pass   | 466      | Pass   | 467      | Pass   | 468      | Pass   |
| 469                                                         | Pass   | 470      | Pass   | 471      | Pass   | 472      | Pass   |
| 473                                                         | Pass   | 474      | Pass   | 475      | Pass   | 476      | Pass   |
| 477                                                         | Pass   | 478      | Pass   | 479      | Pass   | 480      | Pass   |
| 481                                                         | Pass   | 482      | Pass   | 483      | Pass   | 484      | Pass   |
| 485                                                         | Pass   | 486      | Pass   | 487      | Pass   | 488      | Pass   |
| 489                                                         | Pass   | 490      | Pass   | 491      | Pass   | 492      | Pass   |
| 493                                                         | Pass   | 494      | Pass   | 495      | Pass   | 496      | Pass   |
| 497                                                         | Pass   | 498      | Pass   | 499      | Pass   | 500      | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



SIHOR  
(GUJARAT)

**Authorized Signatory**