

HELIUM LEAK DETECTION TEST

TC No.: HLD/KF/LI/HQ9/006/25	Model No.: KFLIHQ-9	Date: 14-07-2025
Type and Capacity of Extinguisher	: KFLIHQ-9-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 9 Ltr.	
Batch Number	: KFLIHQ9 006/25	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00051 To 60	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
51	Pass	52	Pass	53	Pass	54	Pass
55	Pass	56	Pass	57	Pass	58	Pass
59	Pass	60	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory