

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/101/26	Model No.: MARQ-6-40%	Date: 09-04-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 101/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10001 To 10100 And 10005A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10005A and removed from the Lot/Batch							
10001	Pass	10002	Pass	10003	Pass	10004	Pass
10005	Pass	10006	Pass	10007	Pass	10008	Pass
10009	Pass	10010	Pass	10011	Pass	10012	Pass
10013	Pass	10014	Pass	10015	Pass	10016	Pass
10017	Pass	10018	Pass	10019	Pass	10020	Pass
10021	Pass	10022	Pass	10023	Pass	10024	Pass
10025	Pass	10026	Pass	10027	Pass	10028	Pass
10029	Pass	10030	Pass	10031	Pass	10032	Pass
10033	Pass	10034	Pass	10035	Pass	10036	Pass
10037	Pass	10038	Pass	10039	Pass	10040	Pass
10041	Pass	10042	Pass	10043	Pass	10044	Pass
10045	Pass	10046	Pass	10047	Pass	10048	Pass
10049	Pass	10050	Pass	10051	Pass	10052	Pass
10053	Pass	10054	Pass	10055	Pass	10056	Pass
10057	Pass	10058	Pass	10059	Pass	10060	Pass
10061	Pass	10062	Pass	10063	Pass	10064	Pass
10065	Pass	10066	Pass	10067	Pass	10068	Pass
10069	Pass	10070	Pass	10071	Pass	10072	Pass
10073	Pass	10074	Pass	10075	Pass	10076	Pass
10077	Pass	10078	Pass	10079	Pass	10080	Pass
10081	Pass	10082	Pass	10083	Pass	10084	Pass
10085	Pass	10086	Pass	10087	Pass	10088	Pass
10089	Pass	10090	Pass	10091	Pass	10092	Pass
10093	Pass	10094	Pass	10095	Pass	10096	Pass
10097	Pass	10098	Pass	10099	Pass	10100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory