

HYDRO PRESSURE TEST

TC No.: HPT/A2/K/HQ/003/26

Model No.: KFKHQ-2

Date: 17-02-2026

Type and Capacity of Extinguisher : KFKHQ-2-Kanex F Class Kitchen Fire Extinguisher Cap. 2 Ltr.

Batch Number : KFKHQ2 003/26

Batch Quantity : 10.00 Nos.

Serial Numbers : 00021 To 30

Month of Manufacturing : Feb/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00021 To 30 and removed from the Lot/Batch							
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass	26	Pass	27	Pass	28	Pass
29	Pass	30	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**