

# HYDRO PRESSURE TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HPT/A2/K/HQ/004/26        | Model No.: KFKHQ-2                                            | Date: 17-02-2026 |
| Type and Capacity of Extinguisher | : KFKHQ-2-Kanex F Class Kitchen Fire Extinguisher Cap. 2 Ltr. |                  |
| Batch Number                      | : KFKHQ2 004/26                                               |                  |
| Batch Quantity                    | : 10.00 Nos.                                                  |                  |
| Serial Numbers                    | : 00031 To 40                                                 |                  |
| Month of Manufacturing            | : Feb/26                                                      |                  |

| Sr. Nos.                                                           | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00031 To 40 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 31                                                                 | Pass   | 32       | Pass   | 33       | Pass   | 34       | Pass   |
| 35                                                                 | Pass   | 36       | Pass   | 37       | Pass   | 38       | Pass   |
| 39                                                                 | Pass   | 40       | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**