

HYDRO PRESSURE TEST

TC No.: HPT/MM6/SP/RQ/030/25	Model No.: MMSRQ-6	Date: 11-09-2025
Type and Capacity of Extinguisher	: MMSRQ-6-Kanex M Foam SP Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: MMSRQ6 030/25	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00581 To 600 And 585A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 585A and removed from the Lot/Batch							
581	Pass	582	Pass	583	Pass	584	Pass
585	Pass	586	Pass	587	Pass	588	Pass
589	Pass	590	Pass	591	Pass	592	Pass
593	Pass	594	Pass	595	Pass	596	Pass
597	Pass	598	Pass	599	Pass	600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory