

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/016/26

Model No.: KFKHQ-9

Date: 11-04-2026

Type and Capacity of Extinguisher : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFKHQ9 016/26

Batch Quantity : 10 Nos.

Serial Numbers : 00151 To 160

Month of Manufacturing : Apr/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
151	Pass	152	Pass	153	Pass	154	Pass
155	Pass	156	Pass	157	Pass	158	Pass
159	Pass	160	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**