

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/107/26	Model No.: MARQ-6-40%	Date: 14-04-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 107/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10601 To 10700 And 10605A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10605A and removed from the Lot/Batch							
10601	Pass	10602	Pass	10603	Pass	10604	Pass
10605	Pass	10606	Pass	10607	Pass	10608	Pass
10609	Pass	10610	Pass	10611	Pass	10612	Pass
10613	Pass	10614	Pass	10615	Pass	10616	Pass
10617	Pass	10618	Pass	10619	Pass	10620	Pass
10621	Pass	10622	Pass	10623	Pass	10624	Pass
10625	Pass	10626	Pass	10627	Pass	10628	Pass
10629	Pass	10630	Pass	10631	Pass	10632	Pass
10633	Pass	10634	Pass	10635	Pass	10636	Pass
10637	Pass	10638	Pass	10639	Pass	10640	Pass
10641	Pass	10642	Pass	10643	Pass	10644	Pass
10645	Pass	10646	Pass	10647	Pass	10648	Pass
10649	Pass	10650	Pass	10651	Pass	10652	Pass
10653	Pass	10654	Pass	10655	Pass	10656	Pass
10657	Pass	10658	Pass	10659	Pass	10660	Pass
10661	Pass	10662	Pass	10663	Pass	10664	Pass
10665	Pass	10666	Pass	10667	Pass	10668	Pass
10669	Pass	10670	Pass	10671	Pass	10672	Pass
10673	Pass	10674	Pass	10675	Pass	10676	Pass
10677	Pass	10678	Pass	10679	Pass	10680	Pass
10681	Pass	10682	Pass	10683	Pass	10684	Pass
10685	Pass	10686	Pass	10687	Pass	10688	Pass
10689	Pass	10690	Pass	10691	Pass	10692	Pass
10693	Pass	10694	Pass	10695	Pass	10696	Pass
10697	Pass	10698	Pass	10699	Pass	10700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory