

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/157/26	Model No.: MARQ-6-50%	Date: 27-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 157/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15601 To 15700 And 15605A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15605A and removed from the Lot/Batch							
15601	Pass	15602	Pass	15603	Pass	15604	Pass
15605	Pass	15606	Pass	15607	Pass	15608	Pass
15609	Pass	15610	Pass	15611	Pass	15612	Pass
15613	Pass	15614	Pass	15615	Pass	15616	Pass
15617	Pass	15618	Pass	15619	Pass	15620	Pass
15621	Pass	15622	Pass	15623	Pass	15624	Pass
15625	Pass	15626	Pass	15627	Pass	15628	Pass
15629	Pass	15630	Pass	15631	Pass	15632	Pass
15633	Pass	15634	Pass	15635	Pass	15636	Pass
15637	Pass	15638	Pass	15639	Pass	15640	Pass
15641	Pass	15642	Pass	15643	Pass	15644	Pass
15645	Pass	15646	Pass	15647	Pass	15648	Pass
15649	Pass	15650	Pass	15651	Pass	15652	Pass
15653	Pass	15654	Pass	15655	Pass	15656	Pass
15657	Pass	15658	Pass	15659	Pass	15660	Pass
15661	Pass	15662	Pass	15663	Pass	15664	Pass
15665	Pass	15666	Pass	15667	Pass	15668	Pass
15669	Pass	15670	Pass	15671	Pass	15672	Pass
15673	Pass	15674	Pass	15675	Pass	15676	Pass
15677	Pass	15678	Pass	15679	Pass	15680	Pass
15681	Pass	15682	Pass	15683	Pass	15684	Pass
15685	Pass	15686	Pass	15687	Pass	15688	Pass
15689	Pass	15690	Pass	15691	Pass	15692	Pass
15693	Pass	15694	Pass	15695	Pass	15696	Pass
15697	Pass	15698	Pass	15699	Pass	15700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory