

# HYDRO PRESSURE TEST

|                                   |                                                                             |                  |
|-----------------------------------|-----------------------------------------------------------------------------|------------------|
| TC No.: HPT/D25/A50/SP/RQ/003/26  | Model No.: KFDSRQ-25-50%                                                    | Date: 27-01-2026 |
| Type and Capacity of Extinguisher | : KFDSRQ-25-50%-Kanex ABC Dry Powder Stored Pressure Fire Extinguisher Cap. |                  |
| Batch Number                      | : KFDSRQ50%25 003/26                                                        |                  |
| Batch Quantity                    | : 50.00 Nos.                                                                |                  |
| Serial Numbers                    | : 00101 To 150                                                              |                  |
| Month of Manufacturing            | : Jan/26                                                                    |                  |

| Sr. Nos.                                                                                   | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on Cylinder Sr.No. 5A and which is removed from the batch (1st batch) |        |          |        |          |        |          |        |
| 101                                                                                        | Pass   | 102      | Pass   | 103      | Pass   | 104      | Pass   |
| 105                                                                                        | Pass   | 106      | Pass   | 107      | Pass   | 108      | Pass   |
| 109                                                                                        | Pass   | 110      | Pass   | 111      | Pass   | 112      | Pass   |
| 113                                                                                        | Pass   | 114      | Pass   | 115      | Pass   | 116      | Pass   |
| 117                                                                                        | Pass   | 118      | Pass   | 119      | Pass   | 120      | Pass   |
| 121                                                                                        | Pass   | 122      | Pass   | 123      | Pass   | 124      | Pass   |
| 125                                                                                        | Pass   | 126      | Pass   | 127      | Pass   | 128      | Pass   |
| 129                                                                                        | Pass   | 130      | Pass   | 131      | Pass   | 132      | Pass   |
| 133                                                                                        | Pass   | 134      | Pass   | 135      | Pass   | 136      | Pass   |
| 137                                                                                        | Pass   | 138      | Pass   | 139      | Pass   | 140      | Pass   |
| 141                                                                                        | Pass   | 142      | Pass   | 143      | Pass   | 144      | Pass   |
| 145                                                                                        | Pass   | 146      | Pass   | 147      | Pass   | 148      | Pass   |
| 149                                                                                        | Pass   | 150      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



**Authorized Signatory**