

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/106/26	Model No.: MARQ-6-40%	Date: 14-04-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 106/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10501 To 10600 And 10505A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10505A and removed from the Lot/Batch							
10501	Pass	10502	Pass	10503	Pass	10504	Pass
10505	Pass	10506	Pass	10507	Pass	10508	Pass
10509	Pass	10510	Pass	10511	Pass	10512	Pass
10513	Pass	10514	Pass	10515	Pass	10516	Pass
10517	Pass	10518	Pass	10519	Pass	10520	Pass
10521	Pass	10522	Pass	10523	Pass	10524	Pass
10525	Pass	10526	Pass	10527	Pass	10528	Pass
10529	Pass	10530	Pass	10531	Pass	10532	Pass
10533	Pass	10534	Pass	10535	Pass	10536	Pass
10537	Pass	10538	Pass	10539	Pass	10540	Pass
10541	Pass	10542	Pass	10543	Pass	10544	Pass
10545	Pass	10546	Pass	10547	Pass	10548	Pass
10549	Pass	10550	Pass	10551	Pass	10552	Pass
10553	Pass	10554	Pass	10555	Pass	10556	Pass
10557	Pass	10558	Pass	10559	Pass	10560	Pass
10561	Pass	10562	Pass	10563	Pass	10564	Pass
10565	Pass	10566	Pass	10567	Pass	10568	Pass
10569	Pass	10570	Pass	10571	Pass	10572	Pass
10573	Pass	10574	Pass	10575	Pass	10576	Pass
10577	Pass	10578	Pass	10579	Pass	10580	Pass
10581	Pass	10582	Pass	10583	Pass	10584	Pass
10585	Pass	10586	Pass	10587	Pass	10588	Pass
10589	Pass	10590	Pass	10591	Pass	10592	Pass
10593	Pass	10594	Pass	10595	Pass	10596	Pass
10597	Pass	10598	Pass	10599	Pass	10600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory