

# HYDRO PRESSURE TEST

|                                   |                                                                       |                  |
|-----------------------------------|-----------------------------------------------------------------------|------------------|
| TC No.: HPT/KF/LI/HQ9/006/25      | Model No.: KFLIHQ-9                                                   | Date: 12-07-2025 |
| Type and Capacity of Extinguisher | : KFLIHQ-9-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 9 Ltr. |                  |
| Batch Number                      | : KFLIHQ9 006/25                                                      |                  |
| Batch Quantity                    | : 11.00 Nos.                                                          |                  |
| Serial Numbers                    | : 00051 To 60 And 55A                                                 |                  |
| Month of Manufacturing            | : Jul/25                                                              |                  |

| Sr. Nos.                                                   | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 55A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 51                                                         | Pass   | 52       | Pass   | 53       | Pass   | 54       | Pass   |
| 55                                                         | Pass   | 56       | Pass   | 57       | Pass   | 58       | Pass   |
| 59                                                         | Pass   | 60       | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**