

HELIUM LEAK DETECTION TEST

TC No.: HLD/A3/K/HQ/004/26

Model No.: KFKHQ-3

Date: 16-04-2026

Type and Capacity of Extinguisher : KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.

Batch Number : KFKHQ3 004/26

Batch Quantity : 10 Nos.

Serial Numbers : 00031 To 40

Month of Manufacturing : Apr/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
31	Pass	32	Pass	33	Pass	34	Pass
35	Pass	36	Pass	37	Pass	38	Pass
39	Pass	40	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**