

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A90/RQ/018/26     | Model No.: MARQ-6-90%                                          | Date: 15-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ90%6 018/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 01701 To 1800 And 1705A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1701                                                         | Pass   | 1702     | Pass   | 1703     | Pass   | 1704     | Pass   |
| 1705                                                         | Pass   | 1706     | Pass   | 1707     | Pass   | 1708     | Pass   |
| 1709                                                         | Pass   | 1710     | Pass   | 1711     | Pass   | 1712     | Pass   |
| 1713                                                         | Pass   | 1714     | Pass   | 1715     | Pass   | 1716     | Pass   |
| 1717                                                         | Pass   | 1718     | Pass   | 1719     | Pass   | 1720     | Pass   |
| 1721                                                         | Pass   | 1722     | Pass   | 1723     | Pass   | 1724     | Pass   |
| 1725                                                         | Pass   | 1726     | Pass   | 1727     | Pass   | 1728     | Pass   |
| 1729                                                         | Pass   | 1730     | Pass   | 1731     | Pass   | 1732     | Pass   |
| 1733                                                         | Pass   | 1734     | Pass   | 1735     | Pass   | 1736     | Pass   |
| 1737                                                         | Pass   | 1738     | Pass   | 1739     | Pass   | 1740     | Pass   |
| 1741                                                         | Pass   | 1742     | Pass   | 1743     | Pass   | 1744     | Pass   |
| 1745                                                         | Pass   | 1746     | Pass   | 1747     | Pass   | 1748     | Pass   |
| 1749                                                         | Pass   | 1750     | Pass   | 1751     | Pass   | 1752     | Pass   |
| 1753                                                         | Pass   | 1754     | Pass   | 1755     | Pass   | 1756     | Pass   |
| 1757                                                         | Pass   | 1758     | Pass   | 1759     | Pass   | 1760     | Pass   |
| 1761                                                         | Pass   | 1762     | Pass   | 1763     | Pass   | 1764     | Pass   |
| 1765                                                         | Pass   | 1766     | Pass   | 1767     | Pass   | 1768     | Pass   |
| 1769                                                         | Pass   | 1770     | Pass   | 1771     | Pass   | 1772     | Pass   |
| 1773                                                         | Pass   | 1774     | Pass   | 1775     | Pass   | 1776     | Pass   |
| 1777                                                         | Pass   | 1778     | Pass   | 1779     | Pass   | 1780     | Pass   |
| 1781                                                         | Pass   | 1782     | Pass   | 1783     | Pass   | 1784     | Pass   |
| 1785                                                         | Pass   | 1786     | Pass   | 1787     | Pass   | 1788     | Pass   |
| 1789                                                         | Pass   | 1790     | Pass   | 1791     | Pass   | 1792     | Pass   |
| 1793                                                         | Pass   | 1794     | Pass   | 1795     | Pass   | 1796     | Pass   |
| 1797                                                         | Pass   | 1798     | Pass   | 1799     | Pass   | 1800     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**