

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/105/26	Model No.: MARQ-6-50%	Date: 09-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 105/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10401 To 10500 And 10405A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10405A and removed from the Lot/Batch							
10401	Pass	10402	Pass	10403	Pass	10404	Pass
10405	Pass	10406	Pass	10407	Pass	10408	Pass
10409	Pass	10410	Pass	10411	Pass	10412	Pass
10413	Pass	10414	Pass	10415	Pass	10416	Pass
10417	Pass	10418	Pass	10419	Pass	10420	Pass
10421	Pass	10422	Pass	10423	Pass	10424	Pass
10425	Pass	10426	Pass	10427	Pass	10428	Pass
10429	Pass	10430	Pass	10431	Pass	10432	Pass
10433	Pass	10434	Pass	10435	Pass	10436	Pass
10437	Pass	10438	Pass	10439	Pass	10440	Pass
10441	Pass	10442	Pass	10443	Pass	10444	Pass
10445	Pass	10446	Pass	10447	Pass	10448	Pass
10449	Pass	10450	Pass	10451	Pass	10452	Pass
10453	Pass	10454	Pass	10455	Pass	10456	Pass
10457	Pass	10458	Pass	10459	Pass	10460	Pass
10461	Pass	10462	Pass	10463	Pass	10464	Pass
10465	Pass	10466	Pass	10467	Pass	10468	Pass
10469	Pass	10470	Pass	10471	Pass	10472	Pass
10473	Pass	10474	Pass	10475	Pass	10476	Pass
10477	Pass	10478	Pass	10479	Pass	10480	Pass
10481	Pass	10482	Pass	10483	Pass	10484	Pass
10485	Pass	10486	Pass	10487	Pass	10488	Pass
10489	Pass	10490	Pass	10491	Pass	10492	Pass
10493	Pass	10494	Pass	10495	Pass	10496	Pass
10497	Pass	10498	Pass	10499	Pass	10500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory