

HYDRO PRESSURE TEST

TC No.: HPT/MM9/SP/RQ/019/26	Model No.: MMSRQ-9	Date: 19-04-2026
Type and Capacity of Extinguisher	: MMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: MMSRQ9 019/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01801 To 1900 And 1805A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1805A and removed from the Lot/Batch							
1801	Pass	1802	Pass	1803	Pass	1804	Pass
1805	Pass	1806	Pass	1807	Pass	1808	Pass
1809	Pass	1810	Pass	1811	Pass	1812	Pass
1813	Pass	1814	Pass	1815	Pass	1816	Pass
1817	Pass	1818	Pass	1819	Pass	1820	Pass
1821	Pass	1822	Pass	1823	Pass	1824	Pass
1825	Pass	1826	Pass	1827	Pass	1828	Pass
1829	Pass	1830	Pass	1831	Pass	1832	Pass
1833	Pass	1834	Pass	1835	Pass	1836	Pass
1837	Pass	1838	Pass	1839	Pass	1840	Pass
1841	Pass	1842	Pass	1843	Pass	1844	Pass
1845	Pass	1846	Pass	1847	Pass	1848	Pass
1849	Pass	1850	Pass	1851	Pass	1852	Pass
1853	Pass	1854	Pass	1855	Pass	1856	Pass
1857	Pass	1858	Pass	1859	Pass	1860	Pass
1861	Pass	1862	Pass	1863	Pass	1864	Pass
1865	Pass	1866	Pass	1867	Pass	1868	Pass
1869	Pass	1870	Pass	1871	Pass	1872	Pass
1873	Pass	1874	Pass	1875	Pass	1876	Pass
1877	Pass	1878	Pass	1879	Pass	1880	Pass
1881	Pass	1882	Pass	1883	Pass	1884	Pass
1885	Pass	1886	Pass	1887	Pass	1888	Pass
1889	Pass	1890	Pass	1891	Pass	1892	Pass
1893	Pass	1894	Pass	1895	Pass	1896	Pass
1897	Pass	1898	Pass	1899	Pass	1900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory