

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/058/26	Model No.: KFKHQ-6	Date: 13-04-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 058/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00571 To 580 And 575A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 575A and removed from the Lot/Batch							
571	Pass	572	Pass	573	Pass	574	Pass
575	Pass	576	Pass	577	Pass	578	Pass
579	Pass	580	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory