

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A90/RQ/020/26     | Model No.: MARQ-6-90%                                          | Date: 26-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ90%6 020/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 01901 To 2000 And 1905A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1905A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1901                                                         | Pass   | 1902     | Pass   | 1903     | Pass   | 1904     | Pass   |
| 1905                                                         | Pass   | 1906     | Pass   | 1907     | Pass   | 1908     | Pass   |
| 1909                                                         | Pass   | 1910     | Pass   | 1911     | Pass   | 1912     | Pass   |
| 1913                                                         | Pass   | 1914     | Pass   | 1915     | Pass   | 1916     | Pass   |
| 1917                                                         | Pass   | 1918     | Pass   | 1919     | Pass   | 1920     | Pass   |
| 1921                                                         | Pass   | 1922     | Pass   | 1923     | Pass   | 1924     | Pass   |
| 1925                                                         | Pass   | 1926     | Pass   | 1927     | Pass   | 1928     | Pass   |
| 1929                                                         | Pass   | 1930     | Pass   | 1931     | Pass   | 1932     | Pass   |
| 1933                                                         | Pass   | 1934     | Pass   | 1935     | Pass   | 1936     | Pass   |
| 1937                                                         | Pass   | 1938     | Pass   | 1939     | Pass   | 1940     | Pass   |
| 1941                                                         | Pass   | 1942     | Pass   | 1943     | Pass   | 1944     | Pass   |
| 1945                                                         | Pass   | 1946     | Pass   | 1947     | Pass   | 1948     | Pass   |
| 1949                                                         | Pass   | 1950     | Pass   | 1951     | Pass   | 1952     | Pass   |
| 1953                                                         | Pass   | 1954     | Pass   | 1955     | Pass   | 1956     | Pass   |
| 1957                                                         | Pass   | 1958     | Pass   | 1959     | Pass   | 1960     | Pass   |
| 1961                                                         | Pass   | 1962     | Pass   | 1963     | Pass   | 1964     | Pass   |
| 1965                                                         | Pass   | 1966     | Pass   | 1967     | Pass   | 1968     | Pass   |
| 1969                                                         | Pass   | 1970     | Pass   | 1971     | Pass   | 1972     | Pass   |
| 1973                                                         | Pass   | 1974     | Pass   | 1975     | Pass   | 1976     | Pass   |
| 1977                                                         | Pass   | 1978     | Pass   | 1979     | Pass   | 1980     | Pass   |
| 1981                                                         | Pass   | 1982     | Pass   | 1983     | Pass   | 1984     | Pass   |
| 1985                                                         | Pass   | 1986     | Pass   | 1987     | Pass   | 1988     | Pass   |
| 1989                                                         | Pass   | 1990     | Pass   | 1991     | Pass   | 1992     | Pass   |
| 1993                                                         | Pass   | 1994     | Pass   | 1995     | Pass   | 1996     | Pass   |
| 1997                                                         | Pass   | 1998     | Pass   | 1999     | Pass   | 2000     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**