

# HYDRO PRESSURE TEST

|                                   |                                                                         |                  |
|-----------------------------------|-------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD2/A50/RQ/001/26    | Model No.: KMPRQ-2-50%                                                  | Date: 27-01-2026 |
| Type and Capacity of Extinguisher | : KMPRQ-2-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg. |                  |
| Batch Number                      | : KMPRQ50%2 001/26                                                      |                  |
| Batch Quantity                    | : 20.00 Nos.                                                            |                  |
| Serial Numbers                    | : 00001 To 20                                                           |                  |
| Month of Manufacturing            | : Jan/26                                                                |                  |

| Sr. Nos.                                                           | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00001 To 20 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1                                                                  | Pass   | 2        | Pass   | 3        | Pass   | 4        | Pass   |
| 5                                                                  | Pass   | 6        | Pass   | 7        | Pass   | 8        | Pass   |
| 9                                                                  | Pass   | 10       | Pass   | 11       | Pass   | 12       | Pass   |
| 13                                                                 | Pass   | 14       | Pass   | 15       | Pass   | 16       | Pass   |
| 17                                                                 | Pass   | 18       | Pass   | 19       | Pass   | 20       | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**