

HYDRO PRESSURE TEST

TC No.: HPT/D75/A90/RQ/001/26	Model No.: KFDRQ-75-90%	Date: 08-01-2026
Type and Capacity of Extinguisher	: KFDRQ-75-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 75 Kg.	
Batch Number	: KFDRQ90%75 001/26	
Batch Quantity	: 51.00 Nos.	
Serial Numbers	: 00001 To 50 And 5A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No. 5A and which is removed from the batch (1st batch)							
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass	6	Pass	7	Pass	8	Pass
9	Pass	10	Pass	11	Pass	12	Pass
13	Pass	14	Pass	15	Pass	16	Pass
17	Pass	18	Pass	19	Pass	20	Pass
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass	26	Pass	27	Pass	28	Pass
29	Pass	30	Pass	31	Pass	32	Pass
33	Pass	34	Pass	35	Pass	36	Pass
37	Pass	38	Pass	39	Pass	40	Pass
41	Pass	42	Pass	43	Pass	44	Pass
45	Pass	46	Pass	47	Pass	48	Pass
49	Pass	50	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory