

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/156/26	Model No.: MARQ-6-50%	Date: 27-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 156/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15501 To 15600 And 15505A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15505A and removed from the Lot/Batch							
15501	Pass	15502	Pass	15503	Pass	15504	Pass
15505	Pass	15506	Pass	15507	Pass	15508	Pass
15509	Pass	15510	Pass	15511	Pass	15512	Pass
15513	Pass	15514	Pass	15515	Pass	15516	Pass
15517	Pass	15518	Pass	15519	Pass	15520	Pass
15521	Pass	15522	Pass	15523	Pass	15524	Pass
15525	Pass	15526	Pass	15527	Pass	15528	Pass
15529	Pass	15530	Pass	15531	Pass	15532	Pass
15533	Pass	15534	Pass	15535	Pass	15536	Pass
15537	Pass	15538	Pass	15539	Pass	15540	Pass
15541	Pass	15542	Pass	15543	Pass	15544	Pass
15545	Pass	15546	Pass	15547	Pass	15548	Pass
15549	Pass	15550	Pass	15551	Pass	15552	Pass
15553	Pass	15554	Pass	15555	Pass	15556	Pass
15557	Pass	15558	Pass	15559	Pass	15560	Pass
15561	Pass	15562	Pass	15563	Pass	15564	Pass
15565	Pass	15566	Pass	15567	Pass	15568	Pass
15569	Pass	15570	Pass	15571	Pass	15572	Pass
15573	Pass	15574	Pass	15575	Pass	15576	Pass
15577	Pass	15578	Pass	15579	Pass	15580	Pass
15581	Pass	15582	Pass	15583	Pass	15584	Pass
15585	Pass	15586	Pass	15587	Pass	15588	Pass
15589	Pass	15590	Pass	15591	Pass	15592	Pass
15593	Pass	15594	Pass	15595	Pass	15596	Pass
15597	Pass	15598	Pass	15599	Pass	15600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory