

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/095/26	Model No.: KFARQ-4-90%	Date: 14-04-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 095/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09401 To 9500 And 9405A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9405A and removed from the Lot/Batch							
9401	Pass	9402	Pass	9403	Pass	9404	Pass
9405	Pass	9406	Pass	9407	Pass	9408	Pass
9409	Pass	9410	Pass	9411	Pass	9412	Pass
9413	Pass	9414	Pass	9415	Pass	9416	Pass
9417	Pass	9418	Pass	9419	Pass	9420	Pass
9421	Pass	9422	Pass	9423	Pass	9424	Pass
9425	Pass	9426	Pass	9427	Pass	9428	Pass
9429	Pass	9430	Pass	9431	Pass	9432	Pass
9433	Pass	9434	Pass	9435	Pass	9436	Pass
9437	Pass	9438	Pass	9439	Pass	9440	Pass
9441	Pass	9442	Pass	9443	Pass	9444	Pass
9445	Pass	9446	Pass	9447	Pass	9448	Pass
9449	Pass	9450	Pass	9451	Pass	9452	Pass
9453	Pass	9454	Pass	9455	Pass	9456	Pass
9457	Pass	9458	Pass	9459	Pass	9460	Pass
9461	Pass	9462	Pass	9463	Pass	9464	Pass
9465	Pass	9466	Pass	9467	Pass	9468	Pass
9469	Pass	9470	Pass	9471	Pass	9472	Pass
9473	Pass	9474	Pass	9475	Pass	9476	Pass
9477	Pass	9478	Pass	9479	Pass	9480	Pass
9481	Pass	9482	Pass	9483	Pass	9484	Pass
9485	Pass	9486	Pass	9487	Pass	9488	Pass
9489	Pass	9490	Pass	9491	Pass	9492	Pass
9493	Pass	9494	Pass	9495	Pass	9496	Pass
9497	Pass	9498	Pass	9499	Pass	9500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory