

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/018/26	Model No.: KFKHQ-9	Date: 11-04-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 018/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00171 To 180	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00171 To 180 and removed from the Lot/Batch							
171	Pass	172	Pass	173	Pass	174	Pass
175	Pass	176	Pass	177	Pass	178	Pass
179	Pass	180	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory