

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/123/26	Model No.: MARQ-6-40%	Date: 14-05-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 123/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12201 To 12300 And 12205A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12205A and removed from the Lot/Batch							
12201	Pass	12202	Pass	12203	Pass	12204	Pass
12205	Pass	12206	Pass	12207	Pass	12208	Pass
12209	Pass	12210	Pass	12211	Pass	12212	Pass
12213	Pass	12214	Pass	12215	Pass	12216	Pass
12217	Pass	12218	Pass	12219	Pass	12220	Pass
12221	Pass	12222	Pass	12223	Pass	12224	Pass
12225	Pass	12226	Pass	12227	Pass	12228	Pass
12229	Pass	12230	Pass	12231	Pass	12232	Pass
12233	Pass	12234	Pass	12235	Pass	12236	Pass
12237	Pass	12238	Pass	12239	Pass	12240	Pass
12241	Pass	12242	Pass	12243	Pass	12244	Pass
12245	Pass	12246	Pass	12247	Pass	12248	Pass
12249	Pass	12250	Pass	12251	Pass	12252	Pass
12253	Pass	12254	Pass	12255	Pass	12256	Pass
12257	Pass	12258	Pass	12259	Pass	12260	Pass
12261	Pass	12262	Pass	12263	Pass	12264	Pass
12265	Pass	12266	Pass	12267	Pass	12268	Pass
12269	Pass	12270	Pass	12271	Pass	12272	Pass
12273	Pass	12274	Pass	12275	Pass	12276	Pass
12277	Pass	12278	Pass	12279	Pass	12280	Pass
12281	Pass	12282	Pass	12283	Pass	12284	Pass
12285	Pass	12286	Pass	12287	Pass	12288	Pass
12289	Pass	12290	Pass	12291	Pass	12292	Pass
12293	Pass	12294	Pass	12295	Pass	12296	Pass
12297	Pass	12298	Pass	12299	Pass	12300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory