

HYDRO PRESSURE TEST

TC No.: HPT/A6/M/RQ/007/26	Model No.: KFDMSRQ-6	Date: 03-05-2026
Type and Capacity of Extinguisher	: KFDMSRQ-6-Kanex D Type Metal SP Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFDMSRQ6 007/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00121 To 140 And 125A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 125A and removed from the Lot/Batch							
121	Pass	122	Pass	123	Pass	124	Pass
125	Pass	126	Pass	127	Pass	128	Pass
129	Pass	130	Pass	131	Pass	132	Pass
133	Pass	134	Pass	135	Pass	136	Pass
137	Pass	138	Pass	139	Pass	140	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory