

## HELIUM LEAK DETECTION TEST

|                                          |                                                                         |                         |
|------------------------------------------|-------------------------------------------------------------------------|-------------------------|
| <b>TC No.:</b> HLD/MOD10/CA/HQ/006/26    | <b>Model No.:</b> KMCHQ-10-FE36                                         | <b>Date:</b> 19-02-2026 |
| <b>Type and Capacity of Extinguisher</b> | : KMCHQ-10-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 10 Kg. |                         |
| <b>Batch Number</b>                      | : KMCHQ10 006/26                                                        |                         |
| <b>Batch Quantity</b>                    | : 20 Nos.                                                               |                         |
| <b>Serial Numbers</b>                    | : 00101 To 120                                                          |                         |
| <b>Month of Manufacturing</b>            | : Feb/26                                                                |                         |

| Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------|--------|----------|--------|----------|--------|----------|--------|
| 101      | Pass   | 102      | Pass   | 103      | Pass   | 104      | Pass   |
| 105      | Pass   | 106      | Pass   | 107      | Pass   | 108      | Pass   |
| 109      | Pass   | 110      | Pass   | 111      | Pass   | 112      | Pass   |
| 113      | Pass   | 114      | Pass   | 115      | Pass   | 116      | Pass   |
| 117      | Pass   | 118      | Pass   | 119      | Pass   | 120      | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of  $1 \times 10^{-6}$  mbar.l/sec and no any cylinders shows leakage beyond this limit.



**Authorized Signatory**