

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/059/26	Model No.: KFARQ-6-90%	Date: 01-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 059/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05801 To 5900 And 5805A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5805A and removed from the Lot/Batch							
5801	Pass	5802	Pass	5803	Pass	5804	Pass
5805	Pass	5806	Pass	5807	Pass	5808	Pass
5809	Pass	5810	Pass	5811	Pass	5812	Pass
5813	Pass	5814	Pass	5815	Pass	5816	Pass
5817	Pass	5818	Pass	5819	Pass	5820	Pass
5821	Pass	5822	Pass	5823	Pass	5824	Pass
5825	Pass	5826	Pass	5827	Pass	5828	Pass
5829	Pass	5830	Pass	5831	Pass	5832	Pass
5833	Pass	5834	Pass	5835	Pass	5836	Pass
5837	Pass	5838	Pass	5839	Pass	5840	Pass
5841	Pass	5842	Pass	5843	Pass	5844	Pass
5845	Pass	5846	Pass	5847	Pass	5848	Pass
5849	Pass	5850	Pass	5851	Pass	5852	Pass
5853	Pass	5854	Pass	5855	Pass	5856	Pass
5857	Pass	5858	Pass	5859	Pass	5860	Pass
5861	Pass	5862	Pass	5863	Pass	5864	Pass
5865	Pass	5866	Pass	5867	Pass	5868	Pass
5869	Pass	5870	Pass	5871	Pass	5872	Pass
5873	Pass	5874	Pass	5875	Pass	5876	Pass
5877	Pass	5878	Pass	5879	Pass	5880	Pass
5881	Pass	5882	Pass	5883	Pass	5884	Pass
5885	Pass	5886	Pass	5887	Pass	5888	Pass
5889	Pass	5890	Pass	5891	Pass	5892	Pass
5893	Pass	5894	Pass	5895	Pass	5896	Pass
5897	Pass	5898	Pass	5899	Pass	5900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory