

# HYDRO PRESSURE TEST

|                                   |                                                                            |                  |
|-----------------------------------|----------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD2/CA/RQ/005/26     | Model No.: KMCRQ-2                                                         | Date: 23-03-2026 |
| Type and Capacity of Extinguisher | : KMCRQ-2-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 2 Kg. |                  |
| Batch Number                      | : KMCRQ2 005/26                                                            |                  |
| Batch Quantity                    | : 20.00 Nos.                                                               |                  |
| Serial Numbers                    | : 00081 To 100                                                             |                  |
| Month of Manufacturing            | : Mar/26                                                                   |                  |

| Sr. Nos.                                                            | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00081 To 100 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 81                                                                  | Pass   | 82       | Pass   | 83       | Pass   | 84       | Pass   |
| 85                                                                  | Pass   | 86       | Pass   | 87       | Pass   | 88       | Pass   |
| 89                                                                  | Pass   | 90       | Pass   | 91       | Pass   | 92       | Pass   |
| 93                                                                  | Pass   | 94       | Pass   | 95       | Pass   | 96       | Pass   |
| 97                                                                  | Pass   | 98       | Pass   | 99       | Pass   | 100      | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**