



Warranty Certificate

Date: 18-05-2026

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: Fire & Safety House - Rajkot

Warranty Start Date: 18-05-2026

Warranty End Date: 17-05-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFCRQ-2-Kanex CO2 High Pressure Fire Extinguisher Cap. 2 Kg.	29	As Per Annexure – I
2	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	17	As Per Annexure – I
3	MARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	46	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **26-27/K/001343 Dated: 18-05-2026 P.O.No. Mail-04-05-2026** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory

