

HYDRO PRESSURE TEST

TC No.: HPT/A9/M/RQ/009/26	Model No.: KFDMSRQ-9	Date: 08-05-2026
Type and Capacity of Extinguisher	: KFDMSRQ-9-Kanex D Type Metal SP Fire Extinguisher Cap. 9 Kg.	
Batch Number	: KFDMSRQ9 009/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00161 To 180 And 165A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 165A and removed from the Lot/Batch							
161	Pass	162	Pass	163	Pass	164	Pass
165	Pass	166	Pass	167	Pass	168	Pass
169	Pass	170	Pass	171	Pass	172	Pass
173	Pass	174	Pass	175	Pass	176	Pass
177	Pass	178	Pass	179	Pass	180	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory