

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/126/26	Model No.: KFARQ-6-50%	Date: 23-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 126/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12501 To 12600 And 12505A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12505A and removed from the Lot/Batch							
12501	Pass	12502	Pass	12503	Pass	12504	Pass
12505	Pass	12506	Pass	12507	Pass	12508	Pass
12509	Pass	12510	Pass	12511	Pass	12512	Pass
12513	Pass	12514	Pass	12515	Pass	12516	Pass
12517	Pass	12518	Pass	12519	Pass	12520	Pass
12521	Pass	12522	Pass	12523	Pass	12524	Pass
12525	Pass	12526	Pass	12527	Pass	12528	Pass
12529	Pass	12530	Pass	12531	Pass	12532	Pass
12533	Pass	12534	Pass	12535	Pass	12536	Pass
12537	Pass	12538	Pass	12539	Pass	12540	Pass
12541	Pass	12542	Pass	12543	Pass	12544	Pass
12545	Pass	12546	Pass	12547	Pass	12548	Pass
12549	Pass	12550	Pass	12551	Pass	12552	Pass
12553	Pass	12554	Pass	12555	Pass	12556	Pass
12557	Pass	12558	Pass	12559	Pass	12560	Pass
12561	Pass	12562	Pass	12563	Pass	12564	Pass
12565	Pass	12566	Pass	12567	Pass	12568	Pass
12569	Pass	12570	Pass	12571	Pass	12572	Pass
12573	Pass	12574	Pass	12575	Pass	12576	Pass
12577	Pass	12578	Pass	12579	Pass	12580	Pass
12581	Pass	12582	Pass	12583	Pass	12584	Pass
12585	Pass	12586	Pass	12587	Pass	12588	Pass
12589	Pass	12590	Pass	12591	Pass	12592	Pass
12593	Pass	12594	Pass	12595	Pass	12596	Pass
12597	Pass	12598	Pass	12599	Pass	12600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory