

Manufacturer Test Certificate

Doc No: FM-QAC-061

Rev No: 01

Date: 01.06.2023

TC No.: A4/K/HQ/005/26

Model No.: KFKHQ-4

Date: 15-03-2026

Type and Capacity of Extinguisher

: KFKHQ-4-Kanex F Class Kitchen Fire Extinguisher Cap. 4 Ltr.

Batch Number

: KFKHQ4 005/26

Batch Quantity

: 10.00 Nos.

Serial Numbers

: 00041 To 50

Month of Manufacturing

: Mar/26

Date of Inspection

: 15-03-2026

Sr. Nos.	Cl. No.	Tests and Inspection	Requirements	Sampling	Observation
1	--	Construction	Welded Body	All	Pass
2	--	Materials of Construction of Body	Stainless Steel	All	Pass
3	--	Media	Wet Chemical	One	Pass
4	--	Filling tolerance	± 2% by volume	One	Pass
5	--	Min. Eff. discharge time	13 seconds. Sr. No. :00041	One	35 SEC.
6	--	Percentage of Discharge	Not less than 90%	One	95%
7	--	Routine Checks	Leakage test by inverted glass jar placed on the cylinder valve and by dipping in water for 6 hrs	All	Pass
8	--	Retention of Charge following partial discharge	The second pressure or weight shall not be less than 75% of the first after interruption of the discharge. Sr. No. :00042	One	94%
9	--	Hydro test of the body	Test pressure 35 bar, Hold for 2.5 Min.	All	Pass
10	--	Burst test for Body	Minimum 55 bar	One	Pass
11	--	Marking	Standard Instructions	All	Pass

Remarks: This is to certify that the K type Fire Extinguisher of Capacity 4 Ltr. meets the Standard requirements.



Authorized Signatory