

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/185/26	Model No.: MARQ-6-50%	Date: 18-04-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 185/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18401 To 18500 And 18405A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18405A and removed from the Lot/Batch							
18401	Pass	18402	Pass	18403	Pass	18404	Pass
18405	Pass	18406	Pass	18407	Pass	18408	Pass
18409	Pass	18410	Pass	18411	Pass	18412	Pass
18413	Pass	18414	Pass	18415	Pass	18416	Pass
18417	Pass	18418	Pass	18419	Pass	18420	Pass
18421	Pass	18422	Pass	18423	Pass	18424	Pass
18425	Pass	18426	Pass	18427	Pass	18428	Pass
18429	Pass	18430	Pass	18431	Pass	18432	Pass
18433	Pass	18434	Pass	18435	Pass	18436	Pass
18437	Pass	18438	Pass	18439	Pass	18440	Pass
18441	Pass	18442	Pass	18443	Pass	18444	Pass
18445	Pass	18446	Pass	18447	Pass	18448	Pass
18449	Pass	18450	Pass	18451	Pass	18452	Pass
18453	Pass	18454	Pass	18455	Pass	18456	Pass
18457	Pass	18458	Pass	18459	Pass	18460	Pass
18461	Pass	18462	Pass	18463	Pass	18464	Pass
18465	Pass	18466	Pass	18467	Pass	18468	Pass
18469	Pass	18470	Pass	18471	Pass	18472	Pass
18473	Pass	18474	Pass	18475	Pass	18476	Pass
18477	Pass	18478	Pass	18479	Pass	18480	Pass
18481	Pass	18482	Pass	18483	Pass	18484	Pass
18485	Pass	18486	Pass	18487	Pass	18488	Pass
18489	Pass	18490	Pass	18491	Pass	18492	Pass
18493	Pass	18494	Pass	18495	Pass	18496	Pass
18497	Pass	18498	Pass	18499	Pass	18500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory