

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/188/26	Model No.: MARQ-6-50%	Date: 18-04-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 188/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18701 To 18800 And 18705A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18705A and removed from the Lot/Batch							
18701	Pass	18702	Pass	18703	Pass	18704	Pass
18705	Pass	18706	Pass	18707	Pass	18708	Pass
18709	Pass	18710	Pass	18711	Pass	18712	Pass
18713	Pass	18714	Pass	18715	Pass	18716	Pass
18717	Pass	18718	Pass	18719	Pass	18720	Pass
18721	Pass	18722	Pass	18723	Pass	18724	Pass
18725	Pass	18726	Pass	18727	Pass	18728	Pass
18729	Pass	18730	Pass	18731	Pass	18732	Pass
18733	Pass	18734	Pass	18735	Pass	18736	Pass
18737	Pass	18738	Pass	18739	Pass	18740	Pass
18741	Pass	18742	Pass	18743	Pass	18744	Pass
18745	Pass	18746	Pass	18747	Pass	18748	Pass
18749	Pass	18750	Pass	18751	Pass	18752	Pass
18753	Pass	18754	Pass	18755	Pass	18756	Pass
18757	Pass	18758	Pass	18759	Pass	18760	Pass
18761	Pass	18762	Pass	18763	Pass	18764	Pass
18765	Pass	18766	Pass	18767	Pass	18768	Pass
18769	Pass	18770	Pass	18771	Pass	18772	Pass
18773	Pass	18774	Pass	18775	Pass	18776	Pass
18777	Pass	18778	Pass	18779	Pass	18780	Pass
18781	Pass	18782	Pass	18783	Pass	18784	Pass
18785	Pass	18786	Pass	18787	Pass	18788	Pass
18789	Pass	18790	Pass	18791	Pass	18792	Pass
18793	Pass	18794	Pass	18795	Pass	18796	Pass
18797	Pass	18798	Pass	18799	Pass	18800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory