

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA4/A40/RQ/019/26     | Model No.: MARQ-4-40%                                          | Date: 27-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-4-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : MARQ40%4 019/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 01801 To 1900 And 1805A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1805A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1801                                                         | Pass   | 1802     | Pass   | 1803     | Pass   | 1804     | Pass   |
| 1805                                                         | Pass   | 1806     | Pass   | 1807     | Pass   | 1808     | Pass   |
| 1809                                                         | Pass   | 1810     | Pass   | 1811     | Pass   | 1812     | Pass   |
| 1813                                                         | Pass   | 1814     | Pass   | 1815     | Pass   | 1816     | Pass   |
| 1817                                                         | Pass   | 1818     | Pass   | 1819     | Pass   | 1820     | Pass   |
| 1821                                                         | Pass   | 1822     | Pass   | 1823     | Pass   | 1824     | Pass   |
| 1825                                                         | Pass   | 1826     | Pass   | 1827     | Pass   | 1828     | Pass   |
| 1829                                                         | Pass   | 1830     | Pass   | 1831     | Pass   | 1832     | Pass   |
| 1833                                                         | Pass   | 1834     | Pass   | 1835     | Pass   | 1836     | Pass   |
| 1837                                                         | Pass   | 1838     | Pass   | 1839     | Pass   | 1840     | Pass   |
| 1841                                                         | Pass   | 1842     | Pass   | 1843     | Pass   | 1844     | Pass   |
| 1845                                                         | Pass   | 1846     | Pass   | 1847     | Pass   | 1848     | Pass   |
| 1849                                                         | Pass   | 1850     | Pass   | 1851     | Pass   | 1852     | Pass   |
| 1853                                                         | Pass   | 1854     | Pass   | 1855     | Pass   | 1856     | Pass   |
| 1857                                                         | Pass   | 1858     | Pass   | 1859     | Pass   | 1860     | Pass   |
| 1861                                                         | Pass   | 1862     | Pass   | 1863     | Pass   | 1864     | Pass   |
| 1865                                                         | Pass   | 1866     | Pass   | 1867     | Pass   | 1868     | Pass   |
| 1869                                                         | Pass   | 1870     | Pass   | 1871     | Pass   | 1872     | Pass   |
| 1873                                                         | Pass   | 1874     | Pass   | 1875     | Pass   | 1876     | Pass   |
| 1877                                                         | Pass   | 1878     | Pass   | 1879     | Pass   | 1880     | Pass   |
| 1881                                                         | Pass   | 1882     | Pass   | 1883     | Pass   | 1884     | Pass   |
| 1885                                                         | Pass   | 1886     | Pass   | 1887     | Pass   | 1888     | Pass   |
| 1889                                                         | Pass   | 1890     | Pass   | 1891     | Pass   | 1892     | Pass   |
| 1893                                                         | Pass   | 1894     | Pass   | 1895     | Pass   | 1896     | Pass   |
| 1897                                                         | Pass   | 1898     | Pass   | 1899     | Pass   | 1900     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**