

HYDRO PRESSURE TEST

TC No.: HPT/D25/A50/RQ/005/26	Model No.: KFDRQ-25-50%	Date: 11-04-2026
Type and Capacity of Extinguisher	: KFDRQ-25-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 25 Kg.	
Batch Number	: KFDRQ50%25 005/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00201 To 250	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No. 5A and which is removed from the batch (1st batch)							
201	Pass	202	Pass	203	Pass	204	Pass
205	Pass	206	Pass	207	Pass	208	Pass
209	Pass	210	Pass	211	Pass	212	Pass
213	Pass	214	Pass	215	Pass	216	Pass
217	Pass	218	Pass	219	Pass	220	Pass
221	Pass	222	Pass	223	Pass	224	Pass
225	Pass	226	Pass	227	Pass	228	Pass
229	Pass	230	Pass	231	Pass	232	Pass
233	Pass	234	Pass	235	Pass	236	Pass
237	Pass	238	Pass	239	Pass	240	Pass
241	Pass	242	Pass	243	Pass	244	Pass
245	Pass	246	Pass	247	Pass	248	Pass
249	Pass	250	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory