

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/018/26	Model No.: KFARQ-2-90%	Date: 27-03-2026
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 018/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01701 To 1800 And 1705A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1705A and removed from the Lot/Batch							
1701	Pass	1702	Pass	1703	Pass	1704	Pass
1705	Pass	1706	Pass	1707	Pass	1708	Pass
1709	Pass	1710	Pass	1711	Pass	1712	Pass
1713	Pass	1714	Pass	1715	Pass	1716	Pass
1717	Pass	1718	Pass	1719	Pass	1720	Pass
1721	Pass	1722	Pass	1723	Pass	1724	Pass
1725	Pass	1726	Pass	1727	Pass	1728	Pass
1729	Pass	1730	Pass	1731	Pass	1732	Pass
1733	Pass	1734	Pass	1735	Pass	1736	Pass
1737	Pass	1738	Pass	1739	Pass	1740	Pass
1741	Pass	1742	Pass	1743	Pass	1744	Pass
1745	Pass	1746	Pass	1747	Pass	1748	Pass
1749	Pass	1750	Pass	1751	Pass	1752	Pass
1753	Pass	1754	Pass	1755	Pass	1756	Pass
1757	Pass	1758	Pass	1759	Pass	1760	Pass
1761	Pass	1762	Pass	1763	Pass	1764	Pass
1765	Pass	1766	Pass	1767	Pass	1768	Pass
1769	Pass	1770	Pass	1771	Pass	1772	Pass
1773	Pass	1774	Pass	1775	Pass	1776	Pass
1777	Pass	1778	Pass	1779	Pass	1780	Pass
1781	Pass	1782	Pass	1783	Pass	1784	Pass
1785	Pass	1786	Pass	1787	Pass	1788	Pass
1789	Pass	1790	Pass	1791	Pass	1792	Pass
1793	Pass	1794	Pass	1795	Pass	1796	Pass
1797	Pass	1798	Pass	1799	Pass	1800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory