

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/163/26	Model No.: MARQ-6-50%	Date: 03-04-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 163/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16201 To 16300 And 16205A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16205A and removed from the Lot/Batch							
16201	Pass	16202	Pass	16203	Pass	16204	Pass
16205	Pass	16206	Pass	16207	Pass	16208	Pass
16209	Pass	16210	Pass	16211	Pass	16212	Pass
16213	Pass	16214	Pass	16215	Pass	16216	Pass
16217	Pass	16218	Pass	16219	Pass	16220	Pass
16221	Pass	16222	Pass	16223	Pass	16224	Pass
16225	Pass	16226	Pass	16227	Pass	16228	Pass
16229	Pass	16230	Pass	16231	Pass	16232	Pass
16233	Pass	16234	Pass	16235	Pass	16236	Pass
16237	Pass	16238	Pass	16239	Pass	16240	Pass
16241	Pass	16242	Pass	16243	Pass	16244	Pass
16245	Pass	16246	Pass	16247	Pass	16248	Pass
16249	Pass	16250	Pass	16251	Pass	16252	Pass
16253	Pass	16254	Pass	16255	Pass	16256	Pass
16257	Pass	16258	Pass	16259	Pass	16260	Pass
16261	Pass	16262	Pass	16263	Pass	16264	Pass
16265	Pass	16266	Pass	16267	Pass	16268	Pass
16269	Pass	16270	Pass	16271	Pass	16272	Pass
16273	Pass	16274	Pass	16275	Pass	16276	Pass
16277	Pass	16278	Pass	16279	Pass	16280	Pass
16281	Pass	16282	Pass	16283	Pass	16284	Pass
16285	Pass	16286	Pass	16287	Pass	16288	Pass
16289	Pass	16290	Pass	16291	Pass	16292	Pass
16293	Pass	16294	Pass	16295	Pass	16296	Pass
16297	Pass	16298	Pass	16299	Pass	16300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory