

HELIUM LEAK DETECTION TEST

TC No.: HLD/KF/LI/HQ9/008/26	Model No.: KFLIHQ-9	Date: 19-02-2026
Type and Capacity of Extinguisher	: KFLIHQ-9-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 9 Ltr.	
Batch Number	: KFLIHQ9 008/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00071 To 80	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
71	Pass	72	Pass	73	Pass	74	Pass
75	Pass	76	Pass	77	Pass	78	Pass
79	Pass	80	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory