

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/227/RQ/044/26	Model No.: KMCRQ-10-227	Date: 16-05-2026
Type and Capacity of Extinguisher	: KMCRQ-10-227-KMCRQ-10-227-Kanex Clean Agent Modular Hfc227ea Based Fire Extinguisher	
Batch Number	: KMC227RQ10 044/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00431 To 440	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00431 To 440 and removed from the Lot/Batch							
431	Pass	432	Pass	433	Pass	434	Pass
435	Pass	436	Pass	437	Pass	438	Pass
439	Pass	440	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory