

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/217/26	Model No.: MARQ-6-50%	Date: 14-05-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 217/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21601 To 21700 And 21605A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21605A and removed from the Lot/Batch							
21601	Pass	21602	Pass	21603	Pass	21604	Pass
21605	Pass	21606	Pass	21607	Pass	21608	Pass
21609	Pass	21610	Pass	21611	Pass	21612	Pass
21613	Pass	21614	Pass	21615	Pass	21616	Pass
21617	Pass	21618	Pass	21619	Pass	21620	Pass
21621	Pass	21622	Pass	21623	Pass	21624	Pass
21625	Pass	21626	Pass	21627	Pass	21628	Pass
21629	Pass	21630	Pass	21631	Pass	21632	Pass
21633	Pass	21634	Pass	21635	Pass	21636	Pass
21637	Pass	21638	Pass	21639	Pass	21640	Pass
21641	Pass	21642	Pass	21643	Pass	21644	Pass
21645	Pass	21646	Pass	21647	Pass	21648	Pass
21649	Pass	21650	Pass	21651	Pass	21652	Pass
21653	Pass	21654	Pass	21655	Pass	21656	Pass
21657	Pass	21658	Pass	21659	Pass	21660	Pass
21661	Pass	21662	Pass	21663	Pass	21664	Pass
21665	Pass	21666	Pass	21667	Pass	21668	Pass
21669	Pass	21670	Pass	21671	Pass	21672	Pass
21673	Pass	21674	Pass	21675	Pass	21676	Pass
21677	Pass	21678	Pass	21679	Pass	21680	Pass
21681	Pass	21682	Pass	21683	Pass	21684	Pass
21685	Pass	21686	Pass	21687	Pass	21688	Pass
21689	Pass	21690	Pass	21691	Pass	21692	Pass
21693	Pass	21694	Pass	21695	Pass	21696	Pass
21697	Pass	21698	Pass	21699	Pass	21700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory