

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/124/26	Model No.: MARQ-6-40%	Date: 14-05-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 124/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12301 To 12400 And 12305A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12305A and removed from the Lot/Batch							
12301	Pass	12302	Pass	12303	Pass	12304	Pass
12305	Pass	12306	Pass	12307	Pass	12308	Pass
12309	Pass	12310	Pass	12311	Pass	12312	Pass
12313	Pass	12314	Pass	12315	Pass	12316	Pass
12317	Pass	12318	Pass	12319	Pass	12320	Pass
12321	Pass	12322	Pass	12323	Pass	12324	Pass
12325	Pass	12326	Pass	12327	Pass	12328	Pass
12329	Pass	12330	Pass	12331	Pass	12332	Pass
12333	Pass	12334	Pass	12335	Pass	12336	Pass
12337	Pass	12338	Pass	12339	Pass	12340	Pass
12341	Pass	12342	Pass	12343	Pass	12344	Pass
12345	Pass	12346	Pass	12347	Pass	12348	Pass
12349	Pass	12350	Pass	12351	Pass	12352	Pass
12353	Pass	12354	Pass	12355	Pass	12356	Pass
12357	Pass	12358	Pass	12359	Pass	12360	Pass
12361	Pass	12362	Pass	12363	Pass	12364	Pass
12365	Pass	12366	Pass	12367	Pass	12368	Pass
12369	Pass	12370	Pass	12371	Pass	12372	Pass
12373	Pass	12374	Pass	12375	Pass	12376	Pass
12377	Pass	12378	Pass	12379	Pass	12380	Pass
12381	Pass	12382	Pass	12383	Pass	12384	Pass
12385	Pass	12386	Pass	12387	Pass	12388	Pass
12389	Pass	12390	Pass	12391	Pass	12392	Pass
12393	Pass	12394	Pass	12395	Pass	12396	Pass
12397	Pass	12398	Pass	12399	Pass	12400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory