

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/FK/RQ/030/26	Model No.: KMCRQ-5-FK	Date: 03-04-2026
Type and Capacity of Extinguisher	: KMCRQ-5-FK-Kanex Clean Agent FK5112 Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5FK 030/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00291 To 300	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00291 To 300 and removed from the Lot/Batch							
291	Pass	292	Pass	293	Pass	294	Pass
295	Pass	296	Pass	297	Pass	298	Pass
299	Pass	300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory