

HELIUM LEAK DETECTION TEST

TC No.: HLD/WM9/HQ/015/26

Model No.: KFWMSHQ-9

Date: 19-02-2026

Type and Capacity of Extinguisher : KFWMSHQ-9-Water Mist Type Portable Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFWMSHQ9 015/26

Batch Quantity : 10 Nos.

Serial Numbers : 00141 To 150

Month of Manufacturing : Feb/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**